



ELECTRICAL RESEARCH AND DEVELOPMENT ASSOCIATION
 (Accredited by the National Accreditation Board for Testing and Calibration Laboratories, Govt. of India)
 ERDA Road, Makarpura Industrial Estate, Vadodara-390 010, India.
 EPABX : +91 (0265) 2642942, 2642964, 2642377, 3043128 / 29 / 30 / 31 / 33
 Fax : +91 (0265) 2638382
 E-mail : erda@erda.org
 Web : http://www.erda.org



TEST REPORT

SHEET: 1 OF 13

NAME & ADDRESS OF CUSTOMER EPOXY TERMINAL & EQUIPMENT PVT. LTD. Plot No: 6B, Phase III, IDA, Medak District. 502307.	TEST REPORT NO.: RP-1617-060843	
	DATE : 22.03.2017	
	CUSTOMER REF. NO.: NIL	DATE : 23.01.2017
	DATE OF SAMPLE RECEIPT 19.01.2017	DATE OF TESTING 27.01.2017 to 18.03.2017
SAMPLE DESCRIPTION CURRENT TRANSFORMER MFD. BY : EPOXY TERMINAL & EQUIPMENT PVT. LTD. RATIO : 300-600/5-5 A BURDEN : 15/15 VA CLASS : 0.5/5P10 ISF : <10/- SYSTEM VOLTAGE : 11 kV ILV : 12/28/75 kV FREQUENCY : 50 Hz. S.T.C : 25 KA/1 Sec. INSULATION CLASS : E YEAR OF MFG : 2016	SAMPLE IDENTIFICATION SR. NO. : ETE-02 TYPE : INDOOR, RESIN CAST ERDA SAMPLE CODE NO. : ERDA-00179616 DRAWING NO. : 1)ETE-CT-WP01, SHEET NO. 1 OF 2, REV.0 2)ETE-CT-WP01, SHEET NO. 2 OF 2, REV.0 3)ETE-001, REV:00 TEST SPECIFICATION & TEST DETAILS ARE AS PER SHEET NO. 2 OF 13.	
ENCLOSURES: 1) Oscillogram No. : 1814/01 2) Test Circuit Diagram : OLSC/IT/13 3) Photographs of Test sample : As per Annexure-I (As per sheet : 1 OF 1)		
TEST RESULTS : As per sheet: 3 OF 13 to 13 OF 13.		
REMARK : The sample conforms to the requirements of the mentioned standard specification as mentioned in tests no. 1 to 14 on sheet no. 2 OF 13.		
PREPARED BY	CHECKED BY	APPROVED BY (S.B.PATEL)

- Note:**
1. This report relates only to the particular sample received in good condition for testing at ERDA.
 2. This report cannot be reproduced in part under any circumstances.
 3. Publication of this report requires prior permission in writing from Director, ERDA.
 4. Only tests asked for by the customer have been carried out.
 5. In case of any dispute, Vadodara will be the exclusive jurisdiction & shall be construed as where the cause has arisen.

Caution: ERDA is not responsible for the authenticity of photocopied or reproduced test reports. ERDA provides support to customers for verification of the authenticity of test reports issued by ERDA.



TE 2182724



Certificate No. : T-0071

ELECTRICAL RESEARCH AND DEVELOPMENT ASSOCIATION

(Accredited by the National Accreditation Board for Testing and Calibration Laboratories, Govt. of India)

ERDA Road, Makarpura Industrial Estate, Vadodara-390 010, India.

EPABX : +91 (0265) 2642942, 2642964, 2642377, 3043128 / 29 / 30 / 31 / 33

Fax : +91 (0265) 2638382

E-mail : erda@erda.org

Web : http://www.erda.org



TEST REPORT NO. : RP-1617-060843

SHEET : 2 OF 13


DATE : 22.03.2017

TEST DETAILS & TEST SPECIFICATION:

Sr. No.	TESTS	REFERENCE STANDARD
1	Verification of terminal marking and polarity.	Cl. No. 9.2 of IS 2705 (Part 1) : 1992
2	Lightning impulse voltage withstand test.	Cl. No. 9.8 of IS 2705 (Part 1) : 1992
3	Power frequency dry withstand test on primary winding.	Cl. No. 9.3 of IS 2705 (Part 1) : 1992
4	Power frequency dry withstand test on secondary winding.	Cl. No. 9.4 of IS 2705 (Part 1) : 1992
5	Over voltage inter-turn test.	Cl. No. 9.5 of IS 2705 (Part 1) : 1992
6	Partial discharge test.	As per customer's requirement & test procedure followed as per Cl. No. 9.1.2 (e) of IS 2705 (Part 1) : 1992
7	Determination of errors according to the requirements of the appropriate accuracy class. (Before STC test)	Cl. No. 7.2.1 & 7.1.1 of IS 2705 (Part 2):1992 for metering core & Cl. No. 7.2.1 & 7.1.1 of IS 2705 (Part 3):1992 for protection core.
8	Composite error test. (Before STC test)	Cl. No. 7.1.2 & 7.2.2 of IS 2705 (Part 3):1992
9	Short time current test.	Cl. No. 9.6 of IS 2705 (Part 1) : 1992
10	Power frequency dry withstand test on primary winding. (After STC test)	Cl. No. 9.3 of IS 2705 (Part 1) : 1992
11	Power frequency dry withstand test on secondary winding. (After STC test)	Cl. No. 9.4 of IS 2705 (Part 1) : 1992
12	Over voltage inter-turn test. (After STC test)	Cl. No. 9.5 of IS 2705 (Part 1) : 1992
13	Determination of errors according to the requirements of the appropriate accuracy class. (After STC test)	Cl. No. 7.1.1 of IS 2705 (Part 2):1992 for metering core & Cl. No. 7.1.1 of IS 2705 (Part 3):1992 for protection core.
14	Composite error test. (After STC test)	Cl. No. 7.1.2 of IS 2705 (Part 3):1992

PREPARED BY

CHECKED BY



TE 2182707



ELECTRICAL RESEARCH AND DEVELOPMENT ASSOCIATION

(Accredited by the National Accreditation Board for Testing and Calibration Laboratories, Govt. of India)

ERDA Road, Makarpura Industrial Estate, Vadodara-390 010, India.

EPABX : +91 (0265) 2642942, 2642964, 2642377, 3043128 / 29 / 30 / 31 / 33

Fax : +91 (0265) 2638382

E-mail : erda@erda.org

Web : http://www.erda.org



TEST REPORT NO. : RP-1617-060843

SHEET : 3 OF 13

DATE : 22.03.2017

TEST RESULTS:

1. Verification of terminal marking and polarity. (Cl. No. 9.2 of IS 2705 (Part 1) : 1992)

Primary winding terminals : P1-P2

Secondary winding terminals : 1S3-1S2-1S1, 2S3-2S2-2S1


Terminal marking & polarity was found Ok.

Terminal marking was found marked clearly & indelibly.

REMARK: Conforms


PREPARED BY


CHECKED BY



TE 2182708



ELECTRICAL RESEARCH AND DEVELOPMENT ASSOCIATION
(Accredited by the National Accreditation Board for Testing and Calibration Laboratories, Govt. of India)
ERDA Road, Makarpura Industrial Estate, Vadodara-390 010, India.
EPABX : +91 (0265) 2642942, 2642964, 2642377, 3043128 / 29 / 30 / 31 / 33
Fax : +91 (0265) 2638382
E-mail : erda@erda.org
Web : http://www.erda.org



TEST REPORT NO.: RP-1617-060843
DATE : 22.03.2017

SHEET NO.: 4 OF 13

2) LIGHTNING IMPULSE VOLTAGE WITHSTAND TEST

(As per Cl. No.: 9.8 of IS : 2705 (Part-1)-1992)

Atmospheric Condition:

Dry Bulb Temperature : 27.0°C
Wet Bulb Temperature : 22.0°C
Atmospheric Pressure : 756.5 mm of Hg.

Test Parameters:

Rated Voltage : 11 kV
Test Voltage : 75 kVp
No. of shots applied : 05 +ve & 05 -ve Polarity shots
No. of shots recorded : Calibration, First & Last for both Polarities

Calibration Pulse Details :

Peak Magnitude : 50.10 kVp
Wave Shape : 1.272 μ s / 45.03 μ s

Applied Test Voltage		
Sr. No.	Positive Polarity	Negative Polarity
1	75.49 kVp	-75.79 kVp
2	76.03 kVp	-75.77 kVp
3	76.34 kVp	-75.88 kVp
4	75.30 kVp	-74.73 kVp
5	75.63 kVp	-75.27 kVp

PREPARED BY

CHECKED BY

TE 2182698





ELECTRICAL RESEARCH AND DEVELOPMENT ASSOCIATION
(Accredited by the National Accreditation Board for Testing and Calibration Laboratories, Govt. of India)
ERDA Road, Makarpura Industrial Estate, Vadodara-390 010, India.
EPABX : +91 (0265) 2642942, 2642964, 2642377, 3043128 / 29 / 30 / 31 / 33
Fax : +91 (0265) 2638382
E-mail : erda@erda.org
Web : http://www.erda.org




TEST REPORT NO.: RP-1617-060843
DATE : 22.03.2017

SHEET NO.: 5 OF 13

LIGHTNING IMPULSE VOLTAGE TEST ON CURRENT TRANSFORMER

CALIBRATION PULSE




T1 1.272 μ s	T2 45.03 μ s
Up 50.10 kV	

TE 2182699

[Signature]


PREPARED BY



[Signature]
CHECKED BY



ELECTRICAL RESEARCH AND DEVELOPMENT ASSOCIATION
 (Accredited by the National Accreditation Board for Testing and Calibration Laboratories, Govt. of India)
 ERDA Road, Makarpura Industrial Estate, Vadodra-390 010, India.
 EPABX : +91 (0265) 2642942, 2642964, 2642377, 3043128 / 29 / 30 / 31 / 33
 Fax : +91 (0265) 2638382
 E-mail : erda@erda.org
 Web : http://www.erda.org




TEST REPORT NO.: RP-1617-060843
DATE : 22.03.2017


SHEET NO.: 6 OF 13

**LIGHTNING IMPULSE VOLTAGE TEST ON
 CURRENT TRANSFORMER
 POSITIVE POLARITY**

FIRST SHOT




LAST SHOT




FIRST SHOT

NEGATIVE POLARITY



LAST SHOT



Remarks : The sample **"CONFORMS"** to the requirement of aforesaid test specification with respect to the test carried out.

[Signature]

PREPARED BY



[Signature]
CHECKED BY

TE 2182700



Certificate No. : T-0071

ELECTRICAL RESEARCH AND DEVELOPMENT ASSOCIATION
(Accredited by the National Accreditation Board for Testing and Calibration Laboratories, Govt. of India)
ERDA Road, Makarpura Industrial Estate, Vadodra-390 010, India.
EPABX : +91 (0265) 2642942, 2642964, 2642377, 3043128 / 29 / 30 / 31 / 33
Fax : +91 (0265) 2638382
E-mail : erda@erda.org
Web : http://www.erda.org



TEST REPORT NO. : RP-1617-060843

SHEET : 7 OF 13

DATE : 22.03.2017

3. Power frequency dry withstand test on primary winding.

(Cl. No. 9.3 of IS 2705 (Part 1) : 1992)

The power frequency voltage of 28 kV (rms) was applied between the primary winding terminals and earth for one minute duration. The secondary windings terminals and base plate were connected together to earth.

The sample withstood the test voltage without any disruptive discharge.

REMARK: Conforms

4. Power frequency dry withstand test on secondary winding.

(Cl. No. 9.4 of IS 2705 (Part 1) : 1992)

(A) On secondary windings

The power frequency voltage of 3 kV (rms) was applied between the secondary windings terminals (all) connected together and the earth. The primary winding terminals and base plate were shorted and connected to the earth. The test voltage was applied for one minute. There was no disruptive discharge observed.

The sample withstood the test voltage satisfactorily.

(B) Between secondary windings

The power frequency voltage of 3 kV (rms) was applied between the secondary windings terminals (1S1-1S2-1S3) connected together and the earth. The primary winding terminals, other secondary windings terminals and base plate were shorted and connected to the earth. The test voltage was applied for one minute. There was no disruptive discharge observed. The sample withstood the test voltage satisfactorily.

(C) Between Secondary windings


The power frequency voltage of 3 kV (rms) was applied between the secondary windings terminals (2S1-2S2-2S3) connected together and the earth. The primary winding terminals, other secondary windings terminals and base plate were shorted and connected to the earth. The test voltage was applied for one minute. There was no disruptive discharge observed. The sample withstood the test voltage satisfactorily.

REMARK: Conforms

PREPARED BY

CHECKED BY

TE 2182709





ELECTRICAL RESEARCH AND DEVELOPMENT ASSOCIATION
(Accredited by the National Accreditation Board for Testing and Calibration Laboratories, Govt. of India)
ERDA Road, Makarpura Industrial Estate, Vadodara-390 010, India.
EPABX : +91 (0265) 2642942, 2642964, 2642377, 3043128 / 29 / 30 / 31 / 33
Fax : +91 (0265) 2638382
E-mail : erda@erda.org
Web : http://www.erda.org



TEST REPORT NO. : RP-1617-060843

SHEET : 8 OF 13

DATE : 22.03.2017

5. Over voltage inter-turn test. (Cl. No. 9.5 of IS 2705 (Part 1) : 1992)

With the primary winding open circuited, a voltage at rated frequency was applied to the secondary winding terminals (1S1-1S3, 2S1-2S3) such as to produce a secondary limiting current of rms value equals to the rated secondary current (i.e. 5 A for core-1 & 2) for one minute. The sample withstood the applied voltage satisfactorily for one minute.

REMARK: Conforms

6. Partial discharge test. (As per customer's requirement & test procedure followed as per Cl. No. 9.1.2 (e) of IS 2705 (Part 1) : 1992)

NETWORK : Non Effectively earthed Starpoint

The power frequency voltage was applied and raised to the pre-stress voltage level ($1.3 U_m = 15.6 \text{ kV}$, where $U_m = 12 \text{ kV}$) and maintained for 10 seconds. The voltage was then reduced to partial discharge measuring level ($1.1 U_m = 13.2 \text{ kV}$ and $1.1 U_m/\sqrt{3} = 7.62 \text{ kV}$) and maintained for one minute. The partial discharge magnitude measured at the measuring voltage level ($1.1 U_m = 13.2 \text{ kV}$) was **04 pC** & ($1.1 U_m/\sqrt{3} = 7.62$) was **04 pC**.

Note: Specified Limit for $1.1 U_m = 250 \text{ pC}$.

Specified Limit for $1.1 U_m/\sqrt{3} = 50 \text{ pC}$

REMARK: Conforms

7. Determination of errors according to the requirements of the appropriate accuracy class. (Before STC test)

(Cl. No. 7.2.1 & 7.1.1 of IS 2705 (Part 2) : 1992 for metering core &

Cl. No. 7.2.1 & 7.1.1 of IS 2705 (Part 3) : 1992 for protection core.)


a) RATIO: 300/5 A, BURDEN: 15 VA, CLASS: 0.5, Secondary winding terminals: 1S1-1S2

PHASE ANGLE ERROR IN MIN.	RATIO ERROR IN %	% OF RATED CURRENT	RATIO ERROR IN %	PHASE ANGLE ERROR IN MIN.
BURDEN: 100 % at 0.8 Lag. P.F.			BURDEN: 25 % at U. P.F.	
0.91	-0.113	120	0.364	6.82
1.71	-0.140	100	0.360	7.09
6.55	-0.348	20	0.289	10.32
11.01	-0.709	5	0.137	19.32

TE 2182719

PREPARED BY

CHECKED BY





Certificate No. : T-0071

ELECTRICAL RESEARCH AND DEVELOPMENT ASSOCIATION

(Accredited by the National Accreditation Board for Testing and Calibration Laboratories, Govt. of India)

ERDA Road, Makarpura Industrial Estate, Vadodra-390 010, India.

EPABX : +91 (0265) 2642942, 2642964, 2642377, 3043128 / 29 / 30 / 31 / 33

Fax : +91 (0265) 2638382

E-mail : erda@erda.org

Web : http://www.erda.org



TEST REPORT NO. : RP-1617-060843

SHEET : 9 OF 13

DATE : 22.03.2017

b) RATIO: 600/5 A, BURDEN: 15 VA, CLASS: 0.5, Secondary winding terminals: 1S1-1S3

PHASE ANGLE ERROR IN MIN.	RATIO ERROR IN %	% OF RATED CURRENT	RATIO ERROR IN %	PHASE ANGLE ERROR IN MIN.
BURDEN: 100 % at 0.8 Lag. P.F.			BURDEN: 25 % at U. P.F.	
1.38	0.075	120	0.210	2.40
1.56	0.070	100	0.208	2.42
2.61	0.004	20	0.178	3.79
5.51	-0.145	5	0.113	7.74

c) CLASS: 5P, BURDEN: 15 VA @ 0.8 Lag. P. F. Secondary winding terminals: 2S1-2S2

RATIO	Secondary winding terminals	% OF RATED CURRENT	RATIO ERROR IN %	PHASE ANGLE ERROR IN MIN.
300/5 A	2S1-2S2	100	-0.355	2.34

d) CLASS: 5P, BURDEN: 15 VA @ 0.8 Lag. P. F. Secondary winding terminals: 2S1-2S3

RATIO	Secondary winding terminals	% OF RATED CURRENT	RATIO ERROR IN %	PHASE ANGLE ERROR IN MIN.
600/5 A	2S1-2S3	100	-0.105	1.23

REMARK: Conforms

8. Composite error test. (Cl. No. 7.1.2 & 7.2.2 of IS 2705 (Part 3) : 1992) (Before STC test)


Secondary winding terminals	: 2S1-2S2	2S1-2S3
RATIO	: 300/5 A	600/5 A
SLV Computed	: 34.63 V	40.67 V
Excitation Current measured	: 128.1 mA	37.1 mA
Composite Error	: 0.256 %	0.074 %

REMARK: Conforms

PREPARED BY

CHECKED BY

TE 2182711





ELECTRICAL RESEARCH AND DEVELOPMENT ASSOCIATION
 (Accredited by the National Accreditation Board for Testing and Calibration Laboratories, Govt. of India)
 ERDA Road, Makarpura Industrial Estate, Vadodara-390 010, India.
 EPABX : +91 (0265) 2642942, 2642964, 2642377, 3043128 / 29 / 30 / 31 / 33
 Fax : +91 (0265) 2638382
 E-mail : erda@erda.org
 Web : http://www.erda.org



TEST REPORT NO. : RP-1617-060843

SHEET : 10 OF 13

DATE : 22.03.2017

9. Short time current test. (Cl. No. 9.6 of IS 2705 (Part 1) : 1992)

Pre test: As tests mentioned in sheet no. 2 OF 13, 8 OF 13, 9 OF 13 (i. e. Sr. No. 7 & 8)

The short time current test was performed on primary winding connected to source as per test circuit diagram OLSC/IT/13 and secondary winding short circuited through a copper link of negligible impedance.

CT Ratio: 300-600/5-5 A.

Supply Frequency: 50Hz.

Test No.	Oscillogram No.	Short circuit current (kA)		Duration (sec.)	Observation during test
		Peak	Rms		
1.	1814/01	63.480	25.383	1.003	No abnormality observed


Observation after test: - No visible damage was observed.
 - C.T. body was intact.

Post test: As tests mentioned in sheet no. 2 OF 13 & 11 OF 13 to 13 OF 13.
 (i.e. Sr. No. 10 to 14)

REMARK: Conforms

PREPARED BY

CHECKED BY



TE 2182723



Certificate No. : T-0071

ELECTRICAL RESEARCH AND DEVELOPMENT ASSOCIATION
(Accredited by the National Accreditation Board for Testing and Calibration Laboratories, Govt. of India)
ERDA Road, Makarpura Industrial Estate, Vadodara-390 010, India.
EPABX : +91 (0265) 2642942, 2642964, 2642377, 3043128 / 29 / 30 / 31 / 33
Fax : +91 (0265) 2638382
E-mail : erda@erda.org
Web : http://www.erda.org



TEST REPORT NO. : RP-1617-060843

SHEET : 11 OF 13

DATE : 22.03.2017

TEST RESULTS AFTER SHORT TIME CURRENT TEST

10. Power frequency dry withstand test on primary winding.

(Cl. No. 9.3 of IS 2705 (Part 1) : 1992)

The power frequency voltage of 25.2 kV (rms) (i.e. 90% of 28 kV (rms)) was applied between the primary winding terminals and earth for one minute duration.

The secondary windings terminals and base plate were connected together to earth.

The sample withstood the test voltage without any disruptive discharge.

REMARK: Conforms

11. Power frequency dry withstand test on secondary winding.

(Cl. No. 9.4 of IS 2705 (Part 1) : 1992)

(A) On secondary windings

The power frequency voltage of 2.7 kV (rms) (i.e. 90% of 3 kV (rms)) was applied between the secondary windings terminals (all) connected together and the earth.

The primary winding terminals and base plate were shorted and connected to the earth.

The test voltage was applied for one minute. There was no disruptive discharge observed. The sample withstood the test voltage satisfactorily.

(B) Between secondary windings

The power frequency voltage of 2.7 kV (rms) (i.e. 90% of 3 kV (rms)) was applied between the secondary windings terminals (1S1-1S2-1S3) connected together and the earth. The primary winding terminals, other secondary windings terminals and base plate were shorted and connected to the earth. The test voltage was applied for one minute. There was no disruptive discharge observed.

The sample withstood the test voltage satisfactorily.

(C) Between Secondary windings


The power frequency voltage of 2.7 kV (rms) (i.e. 90% of 3 kV (rms)) was applied between the secondary windings terminals (2S1-2S2-2S3) connected together and the earth. The primary winding terminals, other secondary windings terminals and base plate were shorted and connected to the earth. The test voltage was applied for one minute. There was no disruptive discharge observed.

The sample withstood the test voltage satisfactorily.

REMARK: Conforms

PREPARED BY

CHECKED BY



TE 2182717



Certificate No. : T-0071

ELECTRICAL RESEARCH AND DEVELOPMENT ASSOCIATION
(Accredited by the National Accreditation Board for Testing and Calibration Laboratories, Govt. of India)
ERDA Road, Makarpura Industrial Estate, Vadodara-390 010, India.
EPABX : +91 (0265) 2642942, 2642964, 2642377, 3043128 / 29 / 30 / 31 / 33
Fax : +91 (0265) 2638382
E-mail : erda@erda.org
Web : http://www.erda.org



TEST REPORT NO. : RP-1617-060843

SHEET : 12 OF 13

DATE : 22.03.2017

12. Over voltage inter-turn test. (Cl. No. 9.5 of IS 2705 (Part 1) : 1992)

With the primary winding open circuited, a voltage at rated frequency was applied to the secondary winding terminals (1S1-1S3, 2S1-2S3) such as to produce a secondary limiting current of rms value equals to 90 % of rated secondary current (i.e. 4.5 A for core 1 & 2) for one minute.

The sample withstood the applied voltage satisfactorily for one minute.

REMARK: Conforms

13. Determination of errors according to the requirements of the appropriate accuracy class. (Cl. No. 7.1.1 of IS 2705 (Part 2) : 1992 for metering core & Cl. No. 7.1.1 of IS 2705 (Part 3) : 1992 for protection core.)

CURRENT TRANSFORMER:

a)RATIO: 300/5 A, BURDEN: 15 VA, CLASS: 0.5, Secondary winding terminals: 1S1-1S2

Sr. No.	% OF RATED CURRENT	Rated burden (in %)	Power factor: 0.8 Lag. P.F.		Difference in errors after Short circuit withstand capability test.	
			RATIO ERROR IN %	PHASE ANGLE ERROR IN MIN.	RATIO ERROR IN %	PHASE ANGLE ERROR IN MIN.
1.	120	100	-0.133	1.27	0.020	-0.36
2.	100	100	-0.155	2.18	0.015	-0.47
3.	20	100	-0.359	7.04	0.011	-0.49
4.	5	100	-0.736	11.92	0.027	-0.91


b)RATIO: 600/5 A, BURDEN: 15 VA, CLASS: 0.5, Secondary winding terminals: 1S1-1S3

Sr. No.	% OF RATED CURRENT	Rated burden (in %)	Power factor: 0.8 Lag. P.F.		Difference in errors after Short circuit withstand capability test.	
			RATIO ERROR IN %	PHASE ANGLE ERROR IN MIN.	RATIO ERROR IN %	PHASE ANGLE ERROR IN MIN.
1.	120	100	0.059	1.55	0.016	-0.17
2.	100	100	0.054	1.76	0.016	-0.20
3.	20	100	-0.015	3.25	0.019	-0.64
4.	5	100	-0.167	6.38	0.022	-0.87

TE 2182726

PREPARED BY

CHECKED BY





Certificate No. : T-0071

ELECTRICAL RESEARCH AND DEVELOPMENT ASSOCIATION

(Accredited by the National Accreditation Board for Testing and Calibration Laboratories, Govt. of India)

ERDA Road, Makarpura Industrial Estate, Vadodara-390 010, India.

EPABX : +91 (0265) 2642942, 2642964, 2642377, 3043128 / 29 / 30 / 31 / 33

Fax : +91 (0265) 2638382

E-mail : erda@erda.org

Web : http://www.erda.org



TEST REPORT NO. : RP-1617-060843

SHEET : 13 OF 13

DATE : 22.03.2017

c)RATIO: 300/5 A, BURDEN: 15 VA, CLASS: 5P, Secondary winding terminals: 2S1-2S2

Sr. No.	% OF RATED CURRENT	Rated burden (in %)	Power factor: 0.8 Lag. P.F.		Difference in errors after Short circuit withstand capability test.	
			RATIO ERROR IN %	PHASE ANGLE ERROR IN MIN.	RATIO ERROR IN %	PHASE ANGLE ERROR IN MIN.
1.	100	100	-0.365	2.07	0.010	0.27

d)RATIO: 600/5 A, BURDEN: 15 VA, CLASS: 5P, Secondary winding terminals: 2S1-2S3

Sr. No.	% OF RATED CURRENT	Rated burden (in %)	Power factor: 0.8 Lag. P.F.		Difference in errors after Short circuit withstand capability test.	
			RATIO ERROR IN %	PHASE ANGLE ERROR IN MIN.	RATIO ERROR IN %	PHASE ANGLE ERROR IN MIN.
1.	100	100	-0.115	1.11	0.010	0.12

REMARK: Conforms

14. Composite error test. (Cl. No. 7.1.2 of IS 2705 (Part 3) : 1992)


Secondary winding terminals	: 2S1-2S2	2S1-2S3
RATIO	: 300/5 A	600/5 A
SLV Computed	: 34.83 V	40.87 V
Excitation Current measured	: 126.3 mA	37.3 mA
Composite Error	: 0.253 %	0.075 %
Difference	: 0.003%	-0.001%

REMARK: Conforms

PREPARED BY

CHECKED BY

TE 2182715





ELECTRICAL RESEARCH AND DEVELOPMENT ASSOCIATION

(Accredited by the National Accreditation Board for Testing and Calibration Laboratories, Govt. of India)

ERDA Road, Makarpura Industrial Estate, Vadodara-390 010, India.

EPABX : +91 (0265) 2642942, 2642964, 2642377, 3043128 / 29 / 30 / 31 / 33

Fax : +91 (0265) 2638382


E-mail : erda@erda.org

Web : <http://www.erda.org>




TEST REPORT NO. : RP-1617-060843


DATE : 22.03.2017



OSCILLOGRAM NO. : 1814/01



TE 2175706



DATE: 22.03.2017

ELECTRICAL RESEARCH AND
DEVELOPMENT ASSOCIATION

SCHEMATIC CIRCUIT DIAGRAM

DRN.BY	CKD.	DATE	DRG.NO.
--------	------	------	---------

S.B.S.	A.v.B.	29-10-99	OLSC/IT/13
--------	--------	----------	------------



Certificate No. : T-0071

ELECTRICAL RESEARCH AND DEVELOPMENT ASSOCIATION

(Accredited by the National Accreditation Board for Testing and Calibration Laboratories, Govt. of India)

ERDA Road, Makarpura Industrial Estate, Vadodara-390 010, India.

EPABX : +91 (0265) 2642942, 2642964, 2642377, 3043128 / 29 / 30 / 31 / 33

Fax : +91 (0265) 2638382

E-mail : erda@erda.org

Web : http://www.erda.org




Annexure-I

TEST REPORT NO. : RP-1617-060843

SHEET : 1 OF 1

DATE : 22.03.2017

PHOTOGRAPHS OF TEST SAMPLE




CURRENT TRANSFORMER	
CURRENT TRANSFORMER : 300-600/5-5A	TYPE : Indoor, Resin cast
SYSTEM VOLTAGE : 11 KV	CORE I : 15 VA/CL 0.5
ILV : 12/28/75 KV	CORE II : 15 VA/CL 5P10
STC : 25 KA/1 SEC	ISP < 10
SL NO. : ETE-02	FREQUENCY : 50 Hz
DRG NO. : ETE-CT-WP01	IS 2705/1992 :
Year of Mfg. : 2016	INS class E
MFG BY: EPOXY TERMINAL AND EQUIPMENT PVT. LTD. HYDRABAD, INDIA	


TE 2182716

PREPARED BY

CHECKED BY




REV	DESCRIPTION	DATE	APPROVED



Model No.	A	B	C	D	E	F	G	H - INSERT
CT-WP-1	215	310	255	185	70	110	110	M12 x 1.75
CT-WP-3	215	275	255	185	70	110	110	M12 x 1.75
CT-WP-4	178	245	200	132	0	85	110	M10 x 1.5
CT-WP-5	215	300	235	165	60	110	110	M10 x 1.5
CT-WP-6	180	275	235	165	60	110	110	M10 x 1.5
CT-WP-7	135	227	235	165	60	110	110	M10 x 1.5
CT-WP-8	173	220	200	132	0	85	110	M10 x 1.5
CT-WP-9	105	152	190	132	0	85	80	M10 x 1.5
CT-WP-L	320	410	255	190	70	110	110	M12 x 1.75

GENERAL TOLERANCES		GA Drawing for 11KV WOUND PRIMARY CURRENT TRANSFORMER	Third Angle Projection	SIGN		DATE
ISO : 2768-1 C				DRN.		15.03.16
				CHD.		15.03.16
				APPD.		15.03.16

SCALE	EPOXY TERMINAL AND EQUIPMENT PVT. LTD. PLOT. NO: 6B, PHASE: III, IDA, PASHAMYLARAM PATANCHERU, MEDAK (DIST), TELANGANA - 502307	DRG.NO:
%		ETE-001
		REV : 00



TYPE: INDOOR RESIN CAST		QTY:	ALL DIMENSION ARE IN mm				TITLE: CROSS SECTION DRAWING - 11KV WOUND PRIMARY CURRENT TRANSFORMER				SCALE : NTS	
0			PALANI			30/11/16	EPOXY TERMINAL AND EQUIPMENT PVT. LTD. PLOT. NO: 6B, PHASE: III, IDA, PASHAMYLARAM, PATANCHERU, MEDAK (DIST), TELANGANA - 502307					
REV. DATE	DESCRIPTION		DRAWN	CHD.	APPD.	SIGN						
											SHT.No.	DRAWING No.
											1 OF 2	EPE-CT-WP01

WINDING DETAILS :- Refer to this drawing by ERDA is submitted to relevant dimensional checks only. Verified dimensions are marked with '✓'.

PRIMARY WINDING:-
 No. of turns = 1 T,
 Cross section area : (40 x 0.3)mm x 34 parallel = 408 sq.mm
 Material : Copper strip

SECONDARY WINDING:-
 No. of turns : 60 T + 60 T for both core,
 Cross section area :
 Core 1 : 19 SWG x 3 parallel + 16 SWG = 2.43 sq.mm + 2.07 sq.mm
 Core 2 : 18 SWG x 2 parallel + 16 SWG = 2.33 sq.mm + 2.07 sq.mm
 Material : Super Enamelled copper wire

Test Report No. LSCM/RP-1617-0608/3
 Date: 22.03.2017
 Product: 11KV Wound Primary of




RATING LABEL

CURRENT TRANSFORMER


RATIO : 300-600/5-5A CORE I : 15 VA/CL 0.5
 SYSTEM VOLTAGE : 11 KV CORE II : 15 VA/CL 5P10
 ILV : 12/28/75KV ISF<10, TYPE : INDOOR, RESIN CAST
 STC : 25 KA/ 1 SEC FREQUENCY : 50 Hz
 SL.NO. : ETE-02 REF.STANDARD: IS2705/1992
 DRG.NO. : ETE-CT-WP01 INSULATION CLASS : E
 YEAR OF MFD. : 2016

MFD. BY:

EPOXY TERMINAL AND EQUIPMENT PVT. LTD.
 PLOT. NO. 6B, PHASE: III, IDA, PASHAMYLARAM,
 PATANCHERU, MEDAK (DIST), TELANGANA-502307



CONNECTION DIAGRAM



Test Report No. RP-1617-060843
 Date : 22.03.2017
 Product : 11 KV Wound Primary
 Verified By : *[Signature]*
 Verification of this drawing by ERDA is limited to relevant dimensional checks only. Verified dimensions are marked with 'x'.

TYPE: INDOOR RESIN CAST	QTY:	ALL DIMENSION ARE IN mm	TITLE: RATING LABEL - 11KV WOUND PRIMARY CURRENT TRANSFORMER			
0	PALANI					
REV. DATE	DESCRIPTION	DRAWN	CHD.	APPD.	SIGN	DATE.
						30/11/16

SCALE : NTS			
SHEET No.	DRAWING No.		
2 OF 2	ETE-CT-WP01		

EPOXY TERMINAL AND EQUIPMENT PVT. LTD.
 PLOT. NO. 6B, PHASE: III, IDA, PASHAMYLARAM,
 PATANCHERU, MEDAK (DIST), TELANGANA-502307